

AGENDA
YORK COUNTY BUILDING & CODES BOARD OF APPEALS
York County Office Complex
Small Conference room, Suite 103
1070 Heckle Blvd., Rock Hill, South Carolina
April 28, 2010

- I. CALL TO ORDER
- II. ADOPTION OF MINUTES OF SEPTEMBER 15, 2009
- III. INTRODUCTION OF MEMBERS AND GUESTS
- IV. NEW BUSINESS

Richard Davis, representing Trinity Church of the Nazarene, is requesting a variance for the church. The appeal is made for a variance from Section 903.2.1.3 of the International Building Code. The code Group A-3 states "An automatic sprinkler system shall be provided for Group A-3".

The second appeal is made for a variance from Section 1015.1. The code states "Exit or exit access doorways required."

Attachment A – Appeal from Trinity Church of the Nazarene.

Attachment B – Sections from International Code 2006.

Attachment C – Plan Review comments from the Fire Marshal and Commercial Plans Examiner.

- V. ADJOURNMENT

